

HONKANIEMEN LAITOKSELTA LÄHTEVÄN VEDEN LAATU 2015						
	Yksikkö	Lkm	Keskiarvo	Min.	Maks.	STM 461/2000
Lämpötila	°C	13	6	5.9	6.2	-
E.coli	kpl/100 ml	13	0	0	0	<1 (T)
Koliformiset bakteerit	kpl/100 ml	13	0	0	0	<1 (S)
pH		4	7.6	7.5	7.7	<9,5->6,5 (S)
Sähkönjohtavuus	µS/cm	4	150	98	170	<2500 (S)
Sameus	FNU	4	0.12	0.11	0.13	-
Väri	mg/l Pt	2	<5	5	5	-
Rauta	µg/l	4	5.1	4.7	5.7	<200 (S)
Mangaani	µg/l	4	1.3	0.89	2.1	<50 (S)
Kokonaishakkeerit	kpl/ml	13	0.23	0	2	
Enterokokit	kpl/100 ml	2	0	0	0	<1 (T)
Alkaliniteetti	mmol/l	2	0.67	0.66	0.67	-
Hiilidioksid	mg/l	2	1.8	1.3	2.2	-
Asiditeetti	mmol/l	2	0.039	0.03	0.049	-
Hapettuvuus	mg/l	2	<0.5	0.5	0.5	5 (S)
Permanganaattiluku	mg/l	2	<2	2	2	<20 (S)
Nitriittityppi (NO2-N)	mg/l	1	<0,005	0.005	0.005	<0.15 (T)
Nitriitti	mg/l	1	<0,02	0.02	0.2	0,1 (T)
Nitraattityppi (NO3-N)	mg/l	1	0.22	0.22	0.22	<11 (T)
Nitraatti	mg/l	1	0.98	0.98	0.98	50 (T)
Kokonaishakkeerit	mmol/l	2	0.48	0.46	0.49	-
Kokonaishakkeerit	°dH	2	2.7	2.6	2.8	-
Alumiini	µg/l	1	<1	1	1	200 (S)
Kloridi	mg/l	1	14	14	14	250 (S)
Sulfaatti	mg/l	1	20	20	20	250 (S)
Arseeni	µg/l	1	<0.1	0.1	0.1	10 (T)
Elohopea	µg/l	1	<0.005	0.005	0.005	1 (T)
Natrium	mg/l	1	9.1	9.1	9.1	200 (S)
Fluoridi	mg/l	1	0.074	0.074	0.074	1.5 (T)
Tetra- ja trikloorieteeni	µg/l	1	<0.2	0.2	0.2	10 (T)
1,2-dikloorietaani	µg/l	1	<0.5	0.5	0.5	3 (T)
Bentseeni	µg/l	1	<0.1	0.1	0.1	1 (T)
Antimoni	µg/l	1	<0.1	0.1	0.1	5 (T)
Boori	mg/l	1	0.011	0.011	0.011	1 (T)
Seleeni	µg/l	1	<0.1	0.1	0.1	10 (T)
Uraani	µg/l	1	0.076	0.076	0.076	30 (T)
Syanidi	µg/l	1	<5	5	5	50 (T)
Torjunta-aineet	µg/l	1	0	0	0	0.5 (T)
Kloorifenolit	µg/l	1	0	0	0	10 (T)